



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle)

☒ Construction 189575
☐ Decommission ORIGINAL CONSTRUCTION Notice
of Intent Number _____

PROPOSED USE: ☐ Domestic ☐ Industrial ☒ Municipal
☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____
☒ New Well ☐ Reconditioned Method: ☐ Dug ☐ Bored ☐ Driven
☐ Deepened ☐ Cable ☒ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6" inches, drilled 464 ft.
Depth of completed well 463 ft.

CONSTRUCTION DETAILS
Casing ☒ Welded 6" Diam. from +18" ft. to 446 ft.
Installed: ☐ Liner installed _____ Diam. from _____ ft. to _____ ft.
☐ Threaded _____ Diam. from _____ ft. to _____ ft.

Perforations: ☐ Yes ☒ No
Type of perforator used _____
SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: ☒ Yes ☐ No ☒ K-Pac Location 2 @ 446
Manufacturer's Name Johnson
Type 6" Model No. _____
Diam. 6 Slot Size 18 from 446 ft. to 463 ft.
Diam. _____ Slot Size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: ☐ Yes ☒ No ☐ Size of gravel/sand _____
Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 18" ft.
Materials used in seal Bentonite

Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

PUMP: Manufacturer's Name Grundfos
Type 546- H.P. 5HP

WATER LEVELS: Land-surface elevation above mean sea level 900 ft.
Static level 314 ft. below top of well Date 12-29
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 35 gal./min. with 5 ft. drawdown after 17 hrs.
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Date of test 12-29-05
Bailer test 15 gal./min. with 0 ft. drawdown after 27 hrs.

Airstest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No Back

CURRENT

Notice of Intent No. W238153 31-2E-180

Unique Ecology Well ID Tag No. ALT 255

Water Right Permit No. G123895C

Property Owner Name SAUBERG WATER

Well Street Address 380 E. Cottingham

City Coupeville County: Island

Location NE 1/4- 1/4 SE 1/4 Sec 18 Twn 31 R. 2 EWM circle or one WWM

Lat/Long: _____ Lat Deg _____ Lat Min/Sec _____

(s, t, r still REQUIRED): _____ Long Deg _____ Long Min/Sec _____

Tax Parcel No. _____

CONSTRUCTION OR DECOMMISSION PROCEDURE
Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered.
(USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
BROWN TOPSOIL	0	2
Grey HARDPAN + Gravel	2	108
Brown SANDY Clay	108	340
Grey HARD, HARDPAN + ROCK	340	403
Grey Clay - Sandy	403	407
Water SAND + Gravel	407	464

RECEIVED

JAN 30 2006

DEPT OF ECOLOGY

Start Date 12-12-05 Completed Date 12-29-05

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) JOCK RYAN HARRIS

Driller/Engineer/Trainee Signature Jock R. Harris

Driller or Trainee License No. 1364

If trainee, licensed driller's
Signature and License no. _____

Drilling Company WELL DONE DRILLERS

Address 440 Hill Valley Dr.

City, State, Zip Coupeville WA. 98239

Contractor's
Registration No. WELDE1005AB Date 12/31/05

Ecology is an Equal Opportunity Employer. ECY 050-1-20 (Rev 4/01)